



SIRIM QAS INTERNATIONAL SDN. BHD.

(No. Syarikat 199601037981(410334-X))

1, Persiaran Dato' Menteri, Seksyen 2, Peti Surat 7035, 40700 Shah Alam, Selangor Darul Ehsan, Malaysia
Tel : 603-5544 6000 Emel : cserviceqas@sirim.my www.sirim-qas.com.my

File No : P5-014398
Licence No : FL000088

Date : 25/09/2025

LE NAM MEGASHEET (M) SDN. BHD.
736, LORONG PERINDUSTRIAN BUKIT MINYAK 11
TAMAN PERINDUSTRIAN BUKIT MINYAK
14100 BUKIT MINYAK
PULAU PINANG, MALAYSIA

Attn : Mr Seah Choon Aik

Tel No : 04-5016133

Fax No : 04-5016122

Dear Sir/Madam,

Fire Listing Licence

Product : INSULATION PANEL (POLYURETHANE CORE)
Standard : BS 476 : PART 6 : 1989 + A1 : 2009 BS 476 : PART 7 : 1997

With regards to your request for new/renewal/changes of licence(s) under the SIRIM Fire Listing Licence scheme, enclosed please find the copy of the licence(s) and the certification report(s) for your safe keeping.

For enquiry, please contact

Officer Name : NURUL IZZAH BINTI NORZARI
Contact No : 6013-9956587
Email : izzahn@sirim.my

Thank you.

This is a computer generated document. No signature is required.

SIJIL BARANGAN TERSENARAI *Product Listing Certificate*



SIRIM QAS International Sdn. Bhd. dengan ini menganugerahkan kepada
SIRIM QAS International Sdn. Bhd. hereby grants to

LE NAM MEGASHEET (M) SDN. BHD.
736, LORONG PERINDUSTRIAN BUKIT MINYAK 11
TAMAN PERINDUSTRIAN BUKIT MINYAK
14100 BUKIT MINYAK
PULAU PINANG, MALAYSIA

Sijil untuk menggunakan Tanda Barangan Tersenarai
a certificate to use the Listed Product Mark on

INSULATION PANEL (POLYURETHANE CORE)

Please refer to detail in the SCHEDULE

sebagai mematuhi keperluan
as complying with

BS 476 : PART 6 : 1989 + A1 : 2009
BS 476 : PART 7 : 1997



Ts. Md. Adha bin Katni @ Rahmat
Ketua Pegawai Eksekutif
Chief Executive Officer
SIRIM QAS International Sdn. Bhd.



SCHEDULE

LE NAM MEGASHEET (M) SDN. BHD.



SIRIM

Trade Mark : LEDEX
Model : LEDEX PREMIUM WALL PANEL, LEDEX PREMIUM WALL PANEL PLUS
Rating : Fire propagation index, I: 5.6, 6.8, 5.9
Surface spread of flame: Class One;
Nominal core density: 40kg/m³ - 45kg/m³
Type : Flat Panel
Size : Nominal Panel Thickness: 40mm, 50mm & 60mm
Skin Thickness (BMT): 0.3mm & 0.5mm
Test Report No.: 2019FE0790 & 2019FE0791, 2019FE0792 & 2019FE0793, 2025FE0930 & 2025FE0931

Trade Mark : LEDEX
Model : LEDEX Premium Hi-Rib 40 PU Metal Roofing
Rating : Fire propagation index, I: 7.8, 6.8, 7.0;
Surface spread of flame: Class One;
Nominal core density: 25mm (38kg/m³ - 42kg/m³), 50mm & 60mm (40kg/m³ - 45kg/m³)
Type : Corrugated Panel
Size : Nominal Panel Thickness: 25mm, 50mm & 60mm
Skin Thickness (BMT): Outer layer (0.25mm, 0.30mm, 0.35mm, 0.40mm, 0.42mm & 0.48mm), Inner layer (0.25mm)
Test Report No.: 2023FE0236 & 2023FE0237, 2023FE0234 & 2023FE0235, 2023FE0232 & 2023FE0233

Trade Mark : LEDEX
Model : LEDEX URO-SPAN PU METAL STEP ROOFING
Rating : Fire propagation index, I: 3.9;
Surface spread of flame: Class One;
Core density: 35kg/m³ - 40kg/m³
Type : Corrugated Panel
Size : Nominal Panel Thickness: 30mm
Skin Thickness (BMT): Outer layer (0.35mm, 0.40mm, 0.42mm & 0.48mm), Inner layer (0.25mm)
Test Report No.: 2025FE0369 & 2025FE0370

TEST REPORT NO. : 2019FE0790, 2019FE0791, 2019FE0792, 2019FE0793,
2023FE0236, 2023FE0237, 2023FE0234, 2023FE0235,
2023FE0232, 2023FE0233, 2025FE0369, 2025FE0370,
2025FE0930, 2025FE0931

End of page