



SIRIM QAS INTERNATIONAL SDN. BHD.

((No. Syarikat 199601037981(410334-X)))

1, Persiaran Dato' Menteri, Seksyen 2, Peti Surat 7035, 40700 Shah Alam, Selangor Darul Ehsan, Malaysia
Tel : 603-5544 6000 Emel : cserviceqas@sirim.my www.sirim-qas.com.my

File No : P5-023866
Licence No : FL000278

Date : 05/03/2026

LE NAM MEGASHEET (M) SDN. BHD.
NO. 768 LORONG PERUSAHAAN BUKIT MINYAK 9
KAWASAN PERINDUSTRIAN BUKIT MINYAK MK13
14100 SEBERANG PRAI TENGAH
PULAU PINANG, MALAYSIA

Attn : Mr Seah Choon Aik

Tel No : 04-5016133

Fax No : 04-5016122

Dear Sir/Madam,

Fire Listing Licence

Product : INSULATION PANEL (POLYURETHANE CORE)
Standard : BS 476 : PART 6 : 1989 + A1 : 2009 BS 476 : PART 7 : 1997

With regards to your request for new/renewal/changes of licence(s) under the SIRIM Fire Listing Licence scheme, enclosed please find the copy of the licence(s) and the certification report(s) for your safe keeping.

For enquiry, please contact

Officer Name : NURUL IZZAH BINTI NORZARI
Contact No : 6013-9956587
Email : izzahn@sirim.my

Thank you.

This is a computer generated document. No signature is required.

SIJIL BARANGAN TERSENARAI *Product Listing Certificate*



**SIRIM QAS International Sdn. Bhd. dengan ini menganugerahkan kepada
*SIRIM QAS International Sdn. Bhd. hereby grants to***

**LE NAM MEGASHEET (M) SDN. BHD.
NO. 768 LORONG PERUSAHAAN BUKIT MINYAK 9
KAWASAN PERINDUSTRIAN BUKIT MINYAK MK13
14100 SEBERANG PRAI TENGAH
PULAU PINANG, MALAYSIA**

**Sijil untuk menggunakan Tanda Barangan Tersenarai
*a certificate to use the Listed Product Mark on***

INSULATION PANEL (POLYURETHANE CORE)

Please refer to detail in the SCHEDULE

**sebagai mematuhi keperluan
*as complying with***

**BS 476 : PART 6 : 1989 + A1 : 2009
BS 476 : PART 7 : 1997**



Ts. Md. Adha bin Katni @ Rahmat
Ketua Pegawai Eksekutif
Chief Executive Officer
SIRIM QAS International Sdn. Bhd.



SCHEDULE

LE NAM MEGASHEET (M) SDN. BHD.



Trade Mark : Jikowa
Model : Jikowa PU Ceiling Panel
Rating : Fire propagation index, I: 1.8, 1.0;
Surface spread of flame: Class One;
Nominal core density: 40kg/m³
Type : Flat Panel; Skin profile: NG3 & NG4
Size : Panel thickness: 15.0mm
Skin thickness (BMT): Outer skin: 0.30 mm and 0.35 mm; Inner skin: 0.23 mm
Test Report No.: 2026FE0092 & 2026FE0093, 2026FE0094 & 2026FE0095

Trade Mark : Jikowa
Model : Jikowa Embossed PU Ceiling Panel
Rating : Fire propagation index, I: 1.6, 3.3
Surface spread of flame: Class One;
Nominal core density: 40kg/m³
Type : Flat Panel; Skin profile: Embossed
Size : Panel thickness: 15.0mm;
Skin thickness (BMT): Outer skin: 0.30 mm and 0.35 mm; Inner skin: 0.23 mm
Test Report No.: 2026FE0096 & 2026FE0097, 2026FE0098 & 2026FE0099

TEST REPORT NO. : 2026FE0099, 2026FE0098, 2026FE0097, 2026FE0096,
2026FE0095, 2026FE0094, 2026FE0093, 2026FE0092

End of page
